

EU Declaration of Conformity

Issuer's name and address: Omnis Power USA Inc
100 N Howard ST STE R
Spokane WA 99201
USA

Product: Crystalline silicon terrestrial photovoltaic modules

Type designation: OPxxxM60-P1 (xxx=320-355 in step of 5W)
OPxxxM72-P2 (xxx=425-455 in step of 5W)
OPxxxM60-P2 (xxx=355-380 in step of 5W)
OPxxxM66-P2 (xxx=390-415 in step of 5W)
OPxxxM72-P3 (xxx=525-550 in step of 5W)
OPxxxM66-P3 (xxx=485-500 in step of 5W)
OPxxxM60-P3 (xxx=440-455 in step of 5W)
OPxxxM54-P3 (xxx=390-410 in step of 5W)
OPxxxM66-P4 (xxx=635-665 in step of 5W)
OPxxxM60-P4 (xxx=570-605 in step of 5W)
OPxxxM50-P4 (xxx=530-550 in step of 5W)
OPxxxM50-P4 (xxx=485-500 in step of 5W)
OPxxxM40-P4 (xxx=385-400 in step of 5W)

OPxxxM60-P1-B (xxx=285-330 in step of 5W)
OPxxxM72-P2-B (xxx=425-455 in step of 5W)
OPxxxM60-P2-B (xxx=355-380 in step of 5W)
OPxxxM54-P3-B (xxx=390-410 in step of 5W)
OPxxxM40-P4-B (xxx=385-400 in step of 5W)

OPxxxM54-P3-BF (xxx=390 to 415 in step of 5W)
OPxxxM60-P3-BF (xxx=430 to 465 in step of 5W)
OPxxxM72-P3-BF (xxx=525-550 in step of 5W)
OPxxxM72-P3-BF (xxx=520 to 555 in step of 5W)
OPxxxM66-P4-BF (xxx=635-665 in step of 5W)
OPxxxM60-P4-BF (xxx=570-605 in step of 5W)
OPxxxM55-P4-BF (xxx=530-550 in step of 5W)

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2014/35/EU

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/os-cert

The technical documentation and full compliance with the standards listed below proves the conformity of the product with the requirements of the above-mentioned EC Directive:


EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Certificate No. No.Z2 117850 0003 Rev.00 / No.Z2 117850 0005 Rev.00
No.N8A 117850 0006 Ver. 00 / No.N8A 117850 0004 Ver. 00.

This declaration is issued under the sole responsibility of the manufacturer.

WA, USA 2022/11/26

(Place, Date)


(name, function), (signature)



Product Service

Attestation of Conformity

No. N8A 117850 0006 Rev. 00

Holder of Certificate: **Omnis Power USA Inc**
100N Howard St
Spokane WA 99201
USA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062258702-00

Date, 2022-11-24

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 117850 0006 Rev. 00

Model(s):

OPxxxM60-P1 (xxx=320-355 in step of 5W)
 OPxxxM72-P2 (xxx=425-455 in step of 5W)
 OPxxxM60-P2 (xxx=355-380 in step of 5W)
 OPxxxM66-P2 (xxx=390-415 in step of 5W)
 OPxxxM72-P3 (xxx=525-550 in step of 5W)
 OPxxxM66-P3 (xxx=485-500 in step of 5W)
 OPxxxM60-P3 (xxx=440-455 in step of 5W)
 OPxxxM54-P3 (xxx=390-410 in step of 5W)
 OPxxxM66-P4 (xxx=635-665 in step of 5W)
 OPxxxM60-P4 (xxx=570-605 in step of 5W)
 OPxxxM50-P4 (xxx=530-550 in step of 5W)
 OPxxxM50-P4 (xxx=485-500 in step of 5W)
 OPxxxM40-P4 (xxx=385-400 in step of 5W)

Black series:

OPxxxM60-P1-B (xxx=285-330 in step of 5W)
 OPxxxM72-P2-B (xxx=425-455 in step of 5W)
 OPxxxM60-P2-B (xxx=355-380 in step of 5W)
 OPxxxM54-P3-B (xxx=390-410 in step of 5W)
 OPxxxM40-P4-B (xxx=385-400 in step of 5W)

Transparent series:

OPxxxM72-P3-BF (xxx=525-550 in step of 5W)
 OPxxxM66-P4-BF (xxx=635-665 in step of 5W)
 OPxxxM60-P4-BF (xxx=570-605 in step of 5W)
 OPxxxM55-P4-BF (xxx=530-550 in step of 5W)
 xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 117850 0004 Rev. 00

Holder of Certificate: **Omnis Power USA Inc**

100N Howard St
Spokane WA 99201
USA

Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.:

704062258701-00

Date,

2022-10-24

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 117850 0004 Rev. 00

Model(s): OPxxxM72-P3-BF, xxx=520 to 555 in step of 5,
 OPxxxM60-P3-BF, xxx=430 to 465 in step of 5,
 OPxxxM54-P3-BF, xxx=390 to 415 in step of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed,double glass with Junction box,Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class A or C according to UL790

Tested according to: EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06